

# Farrar Green Home

[www.FarrarGreenHome.org](http://www.FarrarGreenHome.org)



## EQ 5 Local Exhaust

### EQ 5.1 Basic local exhaust

- a) [Bathroom](#) and [kitchen](#) exhaust meets ASHRAE Std 62.2 air flow requirement
- b) Fans and ducts are designed to ASHRAE Std 62.2
- c) Air exhausted to outside
- d) [Energy Star labeled bathroom exhaust fans](#)

### EQ 5.2 Enhanced local exhaust

- a) All bathrooms have occupancy sensors